

Water System	Fluoride Levels Detected in Treated Drinking Water as of 8/1/2018	Last Sampled for Fluoride
Apple Valley North	1.2 to 1.7 mg/L	2017
Apple Valley South	0.3 to 0.61 mg/L	2017
Arden	Non-detect to 0.12 mg/L	2017
Artesia	0.28 to 0.5 mg/L	2018
Barstow	0.36 to 0.64 mg/L	2017
Bay Point ^{ff}	0.18 to 0.7 mg/L	2017
Bell-Bell Gardens ^f	0.41 to 0.87 mg/L	2018
Calipatria	0.32 mg/L	2017
Claremont	0.2 to 1.1 mg/L	2017
Clearlake	0.13 mg/L	2018
Cordova	Non-detect	2018
Cowan Heights	0.2 to 0.26 mg/L	2018
Culver City ^{ff}	0.6 to 1.0 mg/L	2017
Cypress Ridge	Non-detect to 0.12 mg/L	2018
Desert View	0.78 to 1 mg/L	2017
Edna Road	0.23 mg/L	2018
Florence-Graham ^f	0.4 to 1.0 mg/L	2018
Hollydale ^f	0.46 to 0.89 mg/L	2018
Lake Marie	0.2 mg/L	2017
Los Osos	Non-detect to 0.16 mg/L	2018
Lucerne	0.11 to 0.65 mg/L	2018
Morongo Del Norte	0.79 mg/L	2017
Morongo Del Sur	0.62 to 0.82 mg/L	2017
Nipomo	Non-detect to 0.3 mg/L	2017
Norwalk ^f	0.33 to 0.89 mg/L	2018
Orcutt ^{ff}	0.18 to 1.1 mg/L	2017
Placentia ^{ff}	0.40 to 0.9 mg/L	2018
San Dimas	0.51 to 0.67 mg/L	2017
Simi Valley ^{ff}	0.55 to 1.3 mg/L	2018
Sisquoc	0.33 to 0.36 mg/L	2018
South Arcadia	0.49 to 0.85 mg/L	2017
South San Gabriel	0.56 to 0.86 mg/L	2016
Southwest ^{fff}	0.41 to 1.1 mg/L	2018
Tanglewood	0.22 mg/L	2018
West Orange	0.45 to 0.49 mg/L	2018
Willowbrook ^f	0.59 to 1.0 mg/L	2018
Wrightwood	0.2 to 0.44 mg/L	2017
Yorba Linda ^{ff}	0.40 to 0.9 mg/L	2018

^f System fluoridates its drinking water

^{ff} System purchases fluoridated water from a wholesale agency or city