

Golden State Water Company  
School Lead Testing Results 3/2017 to 3/2018

System Name	Sample Date	School	Contaminant	Results Range	Unit	Comments
Apple Valley North	5/18/2017	Sycamore Rocks Elementary	Lead	<5	ug/L	All samples non-detect for lead
Apple Valley South	5/5/2017	Mariana Academy	Lead	<5	ug/L	All samples non-detect for lead
Apple Valley South	4/14/2017	Vanguard Preparatory	Lead	<5	ug/L	All samples non-detect for lead
Arden	8/30/2017	General Davie Jr. Primary Center (Edison, Thomas)	Lead	<5	ug/L	All samples non-detect for lead
Arden	11/15/2017	Winterstein Gateway International Charter	Lead	<5	ug/L	All samples non-detect for lead
Artesia	3/30/2017	Our Lady of Fatima School	Lead	<5	ug/L	All samples non-detect for lead
Bay Point	4/12/2017	Riverview Middle School	Lead	<5	ug/L	All samples non-detect for lead
Bay Point	2/16/2017	Bel Air Elementary	Lead	<5	ug/L	All samples non-detect for lead
Bay Point	2/16/2017	Shore Acres Elementary	Lead	<5	ug/L	All samples non-detect for lead
Bay Point	2/16/2017	Rio Vista Elementary	Lead	<5	ug/L	All samples non-detect for lead
Calipatria	4/25/2017	Fremont Primary	Lead	<5	ug/L	All samples non-detect for lead
Calipatria	4/25/2017	Calipatria High School	Lead	<5	ug/L	All samples non-detect for lead
Calipatria	4/25/2017	Bill E. Young Middle School	Lead	<5	ug/L	All samples non-detect for lead
Calipatria	4/25/2017	Grace Smith Elementary	Lead	<5	ug/L	All samples non-detect for lead
Claremont	5/10/2017	Chaparral Elementary School	Lead	<5 - 16	ug/L	One sample tested had 16 ppb of lead. The school relaced the faucet. Resampling and all other school samples were non-detect for lead.
Claremont	5/18/2017	Presbyterian Children's Center	Lead	<5	ug/L	All samples non-detect for lead
Claremont	6/14/2017	Prestige Academy Preschool	Lead	<5	ug/L	All samples non-detect for lead
Claremont	9/6/2017	Islamic Center of Claremont Community School	Lead	<5	ug/L	All samples non-detect for lead
Cordova	8/29/2017	Gold River Discovery Center	Lead	<5 - 7.6	ug/L	One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.
Cowan Heights	11/7/2017	Arroyo Elementary	Lead	<5	ug/L	All samples non-detect for lead
Cypress Ridge	11/7/2017	Mesa Middle School	Lead	<5	ug/L	All samples non-detect for lead
Cypress Ridge	11/7/2017	CR Lopez High School	Lead	<5	ug/L	All samples non-detect for lead
Morongo Del Sur	10/18/2017	Morongo Valley Elementary	Lead	<5	ug/L	All samples non-detect for lead
Nipomo	11/6/2017	Dorothea Lange Elementary	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	3/29/2017	Pacific Christian	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	12/6/2017	Alice Shaw Elementary	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	12/6/2017	Joe Nightingale Elementary	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	12/6/2017	Lakeview Junior High	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	12/7/2017	Patterson Road Elementary	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	12/7/2017	Ralph Dunlap Elementary	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	12/8/2017	Orcutt Junior High	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	12/8/2017	Orcutt Academy High School	Lead	<5	ug/L	All samples non-detect for lead
Orcutt	12/7/2017	Pine Grove Elementary	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/14/2018	El Dorado High School	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/14/2018	Brookhaven Elementary	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/15/2018	Kraemer Middle School	Lead	<5	ug/L	All samples non-detect for lead

Golden State Water Company  
School Lead Testing Results 3/2017 to 3/2018

Placentia	2/15/2018	Valencia High	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/16/2018	George Key	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/15/2018	Golden Elementary	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/22/2018	Col. J.K. Tuffree Middle School & Parkview Home School	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/23/2018	Morse Avenue Elementary	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/23/2018	Sierra Vista Elementary	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/28/2018	John O. Tynes Elementary	Lead	<5	ug/L	All samples non-detect for lead
Placentia	2/28/2018	Ruby Drive Elementary	Lead	<5 - 5.7	ug/L	One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.
Placentia	3/1/2018	El Camino Real Continuation High	Lead	<5	ug/L	All samples non-detect for lead
Placentia	3/2/2018	Melrose Elementary	Lead	<5	ug/L	All samples non-detect for lead
Placentia	3/2/2018	Valadez Middle School Academy	Lead	<5	ug/L	All samples non-detect for lead
San Dimas	5/26/2017	Allen Avenue Elementary	Lead	<5	ug/L	All samples non-detect for lead
San Dimas	5/24/2017	Arma J. Shull Elementary	Lead	<5	ug/L	All samples non-detect for lead
San Dimas	5/26/2017	Chaparral High School	Lead	<5	ug/L	All samples non-detect for lead
San Dimas	5/24/2017	Fred Ekstrand Elementary	Lead	<5	ug/L	All samples non-detect for lead
San Dimas	5/23/2017	Gladstone Elementary	Lead	<5	ug/L	All samples non-detect for lead
San Dimas	5/31/2017	Lone Hill Middle School	Lead	<5	ug/L	All samples non-detect for lead
San Dimas	5/31/2017	San Dimas High	Lead	<5	ug/L	All samples non-detect for lead
San Dimas	9/13/2017	Arrow Montessori School	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/5/2017	Apollo High School	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/7/2017	Atherwood Elementary	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/5/2017	Berylwood Elementary	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/6/2017	Garden Grove Elementary	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/7/2017	Justin Early Learners	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/6/2017	Knolls Elementary	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/5/2017	Mountain View Elementary	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/6/2017	Santa Susana High School	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/5/2017	Simi Valley High School	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/7/2017	Sycamore Elementary	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/7/2017	Vista Elementary	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/5/2017	Simi Institute of Careers & Education	Lead	<5	ug/L	All samples non-detect for lead
Simi Valley	4/5/2017	Simi Valley USD Transportation	Lead	<5	ug/L	All samples non-detect for lead
South Arcadia	3/21/2018	Pearl Preparatory	Lead	<5	ug/L	All samples non-detect for lead
Southwest	4/13/2017	Leuzinger High School	Lead	<5	ug/L	All samples non-detect for lead
Southwest	4/13/2017	Hawthorne High School	Lead	<5	ug/L	All samples non-detect for lead
Southwest	4/27/2017	R. K. Loyde High School	Lead	<5	ug/L	All samples non-detect for lead
Southwest	4/27/2017	Lawndale High School	Lead	<5	ug/L	All samples non-detect for lead

Golden State Water Company  
School Lead Testing Results 3/2017 to 3/2018

Southwest	3/22/2017	Junipero Serra High School	Lead	<5 - 5.9	ug/L	One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.
Southwest	4/26/2017	Carson Christian School	Lead	<5	ug/L	All samples non-detect for lead
Southwest	8/30/2017	Saint Anthony of Padua	Lead	<5 - 6	ug/L	Two samples tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.
Tanglewood	10/18/2017	Arellanas Elementary & Junior High School	Lead	<5	ug/L	All samples non-detect for lead
West Orange	4/4/2017	Los Alamitos Elementary School	Lead	<5	ug/L	All samples non-detect for lead
West Orange	4/6/2017	Lee Elementary School	Lead	<5	ug/L	All samples non-detect for lead
West Orange	4/6/2017	Weaver Elementary School	Lead	<5	ug/L	All samples non-detect for lead
West Orange	4/6/2017	Hopkinson Elementary School	Lead	<5	ug/L	All samples non-detect for lead
West Orange	4/6/2017	Rossmoor Elementary	Lead	<5	ug/L	All samples non-detect for lead
West Orange	4/4/2017	Los Alamitos High	Lead	<5	ug/L	All samples non-detect for lead
West Orange	4/4/2017	Oak Middle School	Lead	<5	ug/L	All samples non-detect for lead
West Orange	4/4/2017	McAuliffe Middle School	Lead	<5	ug/L	All samples non-detect for lead
West Orange	5/24/2017	Robert M. Pyles Elementary	Lead	<5	ug/L	All samples non-detect for lead
West Orange	5/23/2017	Walter Elementary	Lead	<5	ug/L	All samples non-detect for lead
West Orange	2/16/2018	Cypress Community College	Lead	<5	ug/L	All samples non-detect for lead
Yorba Linda	2/20/2018	Bernardo Yorba Middle School	Lead	<5	ug/L	All samples non-detect for lead
Yorba Linda	2/21/2018	Fairmont Elementary	Lead	<5	ug/L	All samples non-detect for lead
Yorba Linda	3/1/2018	Glenknoll Elementary	Lead	<5	ug/L	All samples non-detect for lead

***Please note: All samples were collected in the morning, before fixtures were used or flushed. Water that sits for extended periods of time in contact with lead-containing materials has a higher likelihood of containing lead than water from a tap or drinking fountain that is used often.***

***The drinking water action level for lead is 15 parts per billion (ppb). If a trace amount of lead is detected that is lower than the action level, schools will be advised to flush those faucets or fountains after extended periods of non-use. If samples exceed the action level, Golden State Water will work with those schools to develop a corrective action plan that may include extended flushing, faucet or fountain replacement, or discontinued use of the faucet or fountain.***