

Golden State Water Company
School Lead Testing Results 3/2017 to 7/2018

| System Name | Sample Date | School | Contaminant | Results Range | Unit | Comments |
|--------------------|--|----------------------------------|--------------|---------------|------|--|
| Apple Valley North | 5/18/2017 | Sycamore Rocks School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Arden | 8/30/2017 | General Davies Primary Center | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Arden | 11/15/2017 | Winterstein Gateway Intl Charter | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Apple Valley South | 5/5/2017 | Mariana Academy | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Apple Valley South | 4/14/2017 | Vanguard Prep | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 3/30/2017 | Our Lady of Fatima | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/20/2018 | Burbank Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/20/2018 | Elliott Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/20/2018 | Niemes Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/20/2018 | Ross Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/19/2018 | Hawaiian Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/20/2018 | Kennedy Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/19/2018 | Aloha Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/21/2018 | Artesia High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/21/2018 | Cabrillo Lane School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/19/2018 | Fedde Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/19/2018 | Palms Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/19/2018, 10/3/2018 and 10/19/2018 | Furgeson Elementary School | Lead (total) | <5 - 24 | ug/L | One sample tested had lead above the reporting limit of 5 ppb and another sample had 24 ppb of lead. The school replaced the faucet and piping. Resampling and all other school samples were non-detect for lead. |
| Artesia | 9/19/2018, 10/3/2018 and 10/19/2018 | Melbourne Elementary School | Lead (total) | <5 - 31 | ug/L | One sample tested had 18 ppb of lead. The school replaced the faucet and piping. The first resample of this faucet had 31 ppb of lead; the second resample had 5.3 ppb of lead. All other school samples were non-detect for lead. |
| Artesia | 9/21/2018 | Willow Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/20/2018 | Gahr High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/21/2018 | Haskell Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Artesia | 9/21/2018 | Tetzlaff Middle School | Lead (total) | <5 - 6.4 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Bay Point | 4/12/2017 | Riverview Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Bay Point | 2/16/2018 | Bel Air Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Bay Point | 2/16/2018 | Shore Acres Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Bay Point | 2/16/2018 | Rio Vista Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Barstow | 11/8/2018 | Barstow High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Barstow | 11/15/2018 | Barstow Junior High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Barstow | 11/8/2018 and 12/4/2018 | Barstow STEM Academy | Lead (total) | <5 - 15 | ug/L | Two samples tested had lead above the reporting limit of 5 ppb. One sample location was resampled but still had lead above the reporting limit. The school was advised to flush the sample locations. All other school samples were non-detect for lead. |
| Barstow | 11/9/2018 | Cameron Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Barstow | 11/15/2018 | Central High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Barstow | 11/28/2018 | Crestline Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Barstow | 11/9/2018 | Henderson Elementary School | Lead (total) | <5 - 5.7 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Barstow | 11/27/2018 | Lenwood Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |

Golden State Water Company
School Lead Testing Results 3/2017 to 7/2018

| | | | | | | |
|---------------|------------|--|--------------|----------|------|--|
| Barstow | 11/28/2018 | Montara Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Barstow | 11/27/2018 | Skyline North Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Culver City | 5/17/2018 | Turning Point School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Culver City | 11/29/2018 | Culver City High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Culver City | 11/29/2018 | Culver City Middle School | Lead (total) | <5 - 13 | ug/L | Two samples tested had lead above the reporting limit of 5 ppb. The school was advised to flush the sample locations. All other school samples were non-detect for lead. |
| Culver City | 11/29/2018 | Farragut Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Culver City | 11/29/2018 | La Ballona Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Culver City | 11/29/2018 | Linwood Howe Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Culver City | 11/29/2018 | El Rincon Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Culver City | 11/29/2018 | El Marino Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cowan Heights | 11/7/2017 | Arroyo Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Clearlake | 9/6/2018 | Pomo Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Claremont | 5/10/2017 | Chaparral Elementary | Lead (total) | <5 - 16 | ug/L | One sample tested had 16 ppb of lead. The school replaced the faucet. Resampling and all other school samples were non-detect for lead. |
| Claremont | 5/18/2017 | Claremont Presbyterian Children's Center | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Claremont | 6/14/2017 | Prestige Preschool Academy | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Claremont | 9/6/2017 | Islamic Center of Claremont | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 8/29/2017 | Gold River Discovery Center | Lead (total) | <5 - 7.6 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Cordova | 4/5/2018 | Cordova Gardens Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/11/2018 | Cordova High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/6/2018 | Kinney High School | Lead (total) | <5 - 14 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Cordova | 4/12/2018 | Mills Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/6/2018 | Navigators Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/10/2018 | Peter J. Shields Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/4/2018 | Rancho Cordova Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/5/2018 | Riverview STEM Academy | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/11/2018 | Walnutwood High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/4/2018 | Williamson Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/10/2018 | W.E. Mitchell Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cordova | 4/12/2018 | Cordova Lane Center | Lead (total) | <5 - 6.8 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Calipatria | 4/25/2017 | Fremont Primary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Calipatria | 4/25/2017 | Calipatria High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Calipatria | 4/25/2017 | Bill E. Young Jr. Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Calipatria | 4/25/2017 | Grace Smith Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cypress Ridge | 11/7/2017 | Mesa Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Cypress Ridge | 11/7/2017 | Lopez High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Edna Road | 10/2/2018 | Los Rancho Elementary | Lead (total) | <5 - 6.1 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Los Osos | 10/3/2018 | Monarch Grove Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Los Osos | 11/1/2018 | Wishing Well School | Lead (total) | <5 - 5.5 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |

Golden State Water Company
School Lead Testing Results 3/2017 to 7/2018

| | | | | | | |
|-----------------|------------|---|--------------|----------|------|---|
| Morongo del Sur | 10/18/2017 | Morongo Valley Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Nipomo | 11/6/2017 | Dorothea Lange Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 11/14/2018 | Los Altos Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 11/14/2018 | Loma Vista Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 11/14/2018 | Carmela Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 12/6/2018 | Mofitt Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 12/6/2018 | Foster Road Elementary School | Lead (total) | <5 - 9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Norwalk | 12/14/2018 | Cresson Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 12/14/2018 | Lakeland Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 12/14/2018 | Lakeside Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 12/14/2018 | Paddison Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 12/14/2018 | Studebaker Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Norwalk | 12/14/2018 | William Orr Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 3/29/2017 | Pacific Christian School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 12/6/2017 | Alice Shaw Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 12/6/2017 | Joe Nightingale Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 12/6/2017 | Lakeview Jr. High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 12/7/2017 | Patterson Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 12/7/2017 | Ralph Dunlap Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 12/8/2017 | Orcutt Jr. High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 12/8/2017 | Orcutt Acadmy High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 12/7/2017 | Pine Grove Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 10/11/2018 | Righetti High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Orcutt | 10/11/2018 | Delta High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/14/2018 | El Dorado High | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/14/2018 | Brookhaven Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/15/2018 | Kraemer Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/15/2018 | Valencia High | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/16/2018 | George Key | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/15/2018 | Golden Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/22/2018 | Tuffree Middle and Parkview Home School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/23/2018 | Morse Avenue Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/23/2018 | Sierra Vista Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/28/2018 | John O. Tynes Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 2/28/2018 | Ruby Drive Elementary | Lead (total) | <5 - 5.7 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Placentia | 3/1/2018 | El Camino Real Continuation High | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 3/2/2018 | Melrose Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Placentia | 3/2/2018 | Valadez Middle School Academy | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| South Arcadia | 3/21/2018 | Pearl Prep School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| South Arcadia | 4/26/2018 | Dr Doug Sears Learning Center | Lead (total) | <5 - 5.8 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| South Arcadia | 4/26/2018 | La Rosa Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/26/2017 | Allen Avenue Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/24/2017 | Arma J Shull Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/26/2017 | Chaparral High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |

Golden State Water Company
School Lead Testing Results 3/2017 to 7/2018

| | | | | | | |
|-------------|-----------|--|--------------|----------|------|--|
| San Dimas | 5/24/2017 | Fred Ekstrand Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/23/2017 | Gladstone Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/31/2017 | Lone Hill Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/31/2017 | San Dimas High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/15/2018 | Charter Oak High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/16/2018 | Badillo Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/17/2018 | Cedargrove Elementary School | Lead (total) | <5 - 5.2 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| San Dimas | 5/17/2018 | Glen Oak Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 9/13/2017 | Arrow Montessori School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| San Dimas | 5/3/2018 | Montessori of San Dimas | Lead (total) | <5 - 9.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| San Dimas | 8/22/2018 | Holy Name of Mary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Sisquoc | 3/28/2018 | Benjamin Foxen Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/5/2017 | Apollo High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/7/2017 | Atherwood Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/5/2017 | Berylwood Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/6/2017 | Garden Grove Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/7/2017 | Justin Early Learners | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/6/2017 | Knolls Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/5/2017 | Mountain View Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/6/2017 | Santa Susanna High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/5/2017 | Simi Valley High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/7/2017 | Sycamore Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/7/2017 | Vista Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/5/2017 | Simi Institute of Careers and Technology | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Simi Valley | 4/5/2017 | Simi Valley USD Transportation | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 4/13/2017 | Leuzinger High | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 4/13/2017 | Hawthorne High | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 4/27/2017 | RK Lloyd Continuation School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 4/27/2017 | Lawndale High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 3/22/2017 | Junipero Serra High School | Lead (total) | <5 - 5.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Southwest | 4/26/2017 | Carson Christian School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 8/30/2017 | St. Anthony of Padua | Lead (total) | <5 - 6 | ug/L | Two samples tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Southwest | 4/10/2018 | Vanguard Learning Center | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 4/10/2018 | Bunche Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 4/10/2018 | Enterprise Middle School | Lead (total) | <5 - 9.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Southwest | 4/10/2018 | McKinley Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 5/1/2018 | Juan De Anza Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 5/1/2018 | Peter Burnett Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 5/1/2018 | Dana Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 6/15/2018 | FDR Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 6/15/2018 | Carson School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 6/12/2018 | Twain Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |

Golden State Water Company
School Lead Testing Results 3/2017 to 7/2018

| | | | | | | |
|-------------|-----------------------------------|---|--------------|----------|------|---|
| Southwest | 6/12/2018 | Anderson Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 6/12/2018 | Rogers Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 6/15/2018 | Green Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 6/5/2018 | Addams Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 6/6/2018 | Smith Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 6/6/2018 | Mitchell Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 11/14/2018 | Bud Carson Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 11/14/2018 | Zela Davis School E&W | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 11/14/2018 | Kornblum School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 11/15/2018 | Worthington Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 1/29/2019 | Environmental Charter Middle School - Inglewood | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Southwest | 1/29/2019 | Environmental Charter High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Tanglewood | 10/18/2017 | Arellanes Elem Jr. High | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Willowbrook | 4/3/2018 | Willowbrook Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Willowbrook | 4/10/2018 | Chavez-Tubman Alternative School | Lead (total) | <5 - 5.2 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Willowbrook | 4/10/2018 | Anderson Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Willowbrook | 4/10/2018 | MLK Jr Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/4/2017 | Los Alamitos Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/6/2017 | Richard Henry Lee | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/6/2017 | Weaver School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/6/2017 | Francis Hopkinson | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/6/2017 | Rossmoor Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/4/2017 | Los Alamitos High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/4/2017 | Oak Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/4/2017 | McAuliffe Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 5/24/2017 | Pyles Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 5/23/2017 | Walter Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/11/2018 | Cypress High School | Lead (total) | <5 - 6 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| West Orange | 4/12/2018 | Walker Junior High School | Lead (total) | <5 - 9.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| West Orange | 4/12/2018 | Kennedy High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/16/2018 | Oxford Academy | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 4/17/2018 | Lexington Jr High School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 6/21/2018 | Margaret Landell School | Lead (total) | <5 - 6.6 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| West Orange | 2/16/2018 | Cypress Community College | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 8/15/2018, 9/5/2018 and 9/18/2018 | A.E. Arnold Elementary School | Lead (total) | <5 - 120 | ug/L | One sample tested had lead above the action limit of 15 ppb. The sample location was resampled but still had lead above the reporting limit of 5 ppb. The school was advised to flush the sample location. All other school samples were non-detect for lead. |
| West Orange | 8/15/2018 | Juliet Morris Elementary School | Lead (total) | <5 - 5.8 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| West Orange | 8/14/2018 | Clara J. King Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 8/14/2018 | Frank Vessels Elementary School | Lead (total) | <5 - 9.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |

Golden State Water Company
School Lead Testing Results 3/2017 to 7/2018

| | | | | | | |
|-------------|-----------|------------------------------|--------------|---------|------|--|
| West Orange | 8/28/2018 | Del Sol School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | 9/11/2018 | Wisdom Mission School | Lead (total) | <5 - 11 | ug/L | Three samples tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| West Orange | 9/11/2018 | Grace Christian School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| West Orange | | | | | | |
| Wrightwood | 4/25/2018 | Wrightwood Elementary School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Yorba Linda | 2/20/2018 | Bernardo Yorba Middle School | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Yorba Linda | 2/21/2018 | Fairmont Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |
| Yorba Linda | 3/1/2018 | Glenknoll Elementary | Lead (total) | <5 | ug/L | All samples non-detect for lead |

Please note: All samples were collected in the morning before fixtures were used or flushed. Water that sits for extended periods of time in contact with lead-containing materials has a higher likelihood of containing lead than water from a tap or drinking fountain that is used often.

The drinking water action level for lead is 15 parts per billion (ppb). If a trace amount of lead is detected that is lower than the action level, schools will be advised to flush those faucets or fountains after extended periods of non-use. If samples exceed the action level, Golden State Water will work with those schools to develop a corrective action plan that may include extended flushing, faucet or fountain replacement, or discontinued use of the faucet or fountain.