

Golden State Water Company  
School Lead Testing Results 3/2017 to 9/2019

| System Name        | Sample Date                            | School  | Contaminant  | Results Range | Unit | Comments   |
|--------------------|--|---|--------------|---------------|------|--|
| Apple Valley North | 5/18/2017                              | Sycamore Rocks Elementary School                  | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Apple Valley South | 5/5/2017                               | Mariana Academy                                   | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Apple Valley South | 4/14/2017                              | Vanguard Preparatory School                       | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Arden              | 8/30/2017                              | General Davie Jr. Primary Center (Edison, Thomas) | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Arden              | 11/15/2017                             | Winterstein Gateway International Charter         | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 3/30/2017                              | Our Lady of Fatima School                         | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/20/2018                              | Burbank Elementary School                         | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/20/2018                              | Elliott Elementary School                         | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/20/2018                              | Niemes Elementary School                          | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/20/2018                              | Ross Middle School                                | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/19/2018                              | Hawaiian Elementary School                        | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/20/2018                              | Kennedy Elementary School                         | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/19/2018                              | Aloha Elementary School                           | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/21/2018                              | Artesia High School                               | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/21/2018                              | Cabrillo Lane School                              | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/19/2018                              | Fedde Middle School                               | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/19/2018                              | Palms Elementary School                           | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/19/2018, 10/3/2018<br>and 10/19/2018 | Furgeson Elementary School                        | Lead (total) | <5 - 24       | ug/L | One sample tested had lead above the reporting limit of 5 ppb and another sample had 24 ppb of lead. The school replaced the faucet and piping. Resampling and all other school samples were non-detect for lead.  |
| Artesia            | 9/19/2018, 10/3/2018<br>and 10/19/2018 | Melbourne Elementary School                       | Lead (total) | <5 - 31       | ug/L | One sample tested had 18 ppb of lead. The school replaced the faucet and piping. The first resample of this faucet had 31 ppb of lead; the second resample had 5.3 ppb of lead. All other school samples were non-detect for lead.                       |
| Artesia            | 9/21/2018                              | Willow Elementary School                          | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/20/2018                              | Gahr High School                                  | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/21/2018                              | Haskell Middle School                             | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Artesia            | 9/21/2018                              | Tetzlaff Middle School                            | Lead (total) | <5 - 6.4      | ug/L | One sample had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.   |
| Bay Point          | 4/12/2017                              | Riverview Middle School                           | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Bay Point          | 2/16/2017                              | Bel Air Elementary School                         | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Bay Point          | 2/16/2017                              | Shore Acres Elementary School                     | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Bay Point          | 2/16/2017                              | Rio Vista Elementary School                       | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Barstow            | 11/8/2018                              | Barstow High School                               | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Barstow            | 11/15/2018                             | Barstow Junior High School                        | Lead (total) | <5            | ug/L | All samples non-detect for lead  |
| Barstow            | 11/8/2018 and 12/4/2018                | Barstow STEM Academy                              | Lead (total) | <5 - 15       | ug/L | Two samples tested had lead above the reporting limit of 5 ppb. One sample location was resampled but still had lead above the reporting limit. The school was advised to flush the sample locations. All other school samples were non-detect for lead. |
| Barstow            | 11/9/2018                              | Cameron Elementary School                         | Lead (total) | <5            | ug/L | All samples non-detect for lead  |

Golden State Water Company  
School Lead Testing Results 3/2017 to 9/2019

|                   |            |  |              |          |      |  |
|-------------------|------------|--|--------------|----------|------|--|
| Barstow           | 11/15/2018 | Central High School                          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Barstow           | 11/28/2018 | Crestline Elementary School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Barstow           | 11/9/2018  | Henderson Elementary School                  | Lead (total) | <5 - 5.7 | ug/L | One sample had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.                             |
| Barstow           | 11/27/2018 | Lenwood Elementary School                    | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Barstow           | 11/28/2018 | Montara Elementary School                    | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Barstow           | 11/27/2018 | Skyline North Elementary School              | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Bell-Bell Gardens | 9/4/2019   | Bell Gardens Elementary School               | Lead (total) | <5 - 6.0 | ug/L | One sample had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.                             |
| Bell-Bell Gardens | 9/4/2019   | Bell Gardens Intermediate School             | Lead (total) | <5 - 5.4 | ug/L | One sample had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.                             |
| Bell-Bell Gardens | 9/4/2019   | Cesar Chavez Elementary School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Bell-Bell Gardens | 9/4/2019   | Garfield Elementary School                   | Lead (total) | <5 - 9.1 | ug/L | Two samples had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.                            |
| Calipatria        | 4/25/2017  | Fremont Primary School                       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Calipatria        | 4/25/2017  | Calipatria High School                       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Calipatria        | 4/25/2017  | Bill E. Young Middle School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Calipatria        | 4/25/2017  | Grace Smith Elementary School                | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Claremont         | 5/10/2017  | Chaparral Elementary School                  | Lead (total) | <5 - 16  | ug/L | One sample tested had 16 ppb of lead. The school relaced the faucet. Resampling and all other school samples were non-detect for lead. |
| Claremont         | 5/18/2017  | Presbyterian Children's Center               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Claremont         | 6/14/2017  | Prestige Academy Preschool                   | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Claremont         | 9/6/2017   | Islamic Center of Claremont Community School | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Clearlake         | 9/6/2018   | Pomo Elementary School                       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 8/29/2017  | Gold River Discovery Center                  | Lead (total) | <5 - 7.6 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.                      |
| Cordova           | 4/5/2018   | Cordova Gardens Elementary School            | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/11/2018  | Cordova High School                          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/6/2018   | Kinney High School                           | Lead (total) | <5 - 14  | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.                      |
| Cordova           | 4/12/2018  | Mills Middle School                          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/6/2018   | Navigator Elementary School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/10/2018  | Peter J. Shields Elementary School           | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/4/2018   | Rancho Cordova Elementary School             | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/5/2018   | Riverview STEM Academy                       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/11/2018  | Walnutwood High School                       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/4/2018   | Williamson Elementary School                 | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/10/2018  | W.E. Mitchell Middle School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cordova           | 4/12/2018  | Cordova Lane Center                          | Lead (total) | <5 - 6.8 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.                      |
| Cowan Heights     | 11/7/2017  | Arroyo Elementary School                     | Lead (total) | <5       | ug/L | All samples non-detect for lead  |

Golden State Water Company  
School Lead Testing Results 3/2017 to 9/2019

|                 |            |                                     |              |          |      |  |
|-----------------|------------|-------------------------------------|--------------|----------|------|--|
| Culver City     | 11/29/2018 | Turning Point School                | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Culver City     | 11/30/2018 | Culver City High School             | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Culver City     | 12/1/2018  | Culver City Middle School           | Lead (total) | <5 - 13  | ug/L | Two samples tested had lead above the reporting limit of 5 ppb. The school was advised to flush the sample locations. All other school samples were non-detect for lead. |
| Culver City     | 12/2/2018  | Farragut Elementary School          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Culver City     | 12/3/2018  | La Ballona Elementary School        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Culver City     | 12/4/2018  | Linwood Howe Elementary School      | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Culver City     | 12/5/2018  | El Rincon Elementary School         | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Culver City     | 12/6/2018  | El Marino Elementary School         | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cypress Ridge   | 11/7/2017  | Mesa Middle School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Cypress Ridge   | 11/7/2017  | CR Lopez High School                | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Edna Road       | 10/2/2018  | Los Ranchos Elementary School       | Lead (total) | <5 - 6.1 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| Florence Graham | 2/20/2019  | Animo Pat Brown Charter High School | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Los Osos        | 10/3/2018  | Monarch Grove Elementary School     | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Los Osos        | 11/1/2018  | Wishing Well School                 | Lead (total) | <5 - 5.5 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| Morongo Del Sur | 10/18/2017 | Morongo Valley Elementary School    | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Nipomo          | 11/6/2017  | Dorothea Lange Elementary School    | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 11/14/2018 | Los Altos Elementary School         | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 11/14/2018 | Loma Vista Elementary School        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 11/14/2018 | Carmela Elementary School           | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 12/6/2018  | Mofitt Elementary School            | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 12/6/2018  | Foster Road Elementary School       | Lead (total) | <5 - 9   | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| Norwalk         | 12/14/2018 | Cresson Elementary School           | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 12/14/2018 | Lakeland Elementary School          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 12/14/2018 | Lakeside Middle School              | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 12/14/2018 | Paddison Elementary School          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 12/14/2018 | Studebaker Elementary School        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Norwalk         | 12/14/2018 | William Orr Elementary School       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 3/29/2017  | Pacific Christian School            | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 12/6/2017  | Alice Shaw Elementary School        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 12/6/2017  | Joe Nightingale Elementary School   | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 12/6/2017  | Lakeview Junior High School         | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 12/7/2017  | Patterson Road Elementary School    | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 12/7/2017  | Ralph Dunlap Elementary School      | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 12/8/2017  | Orcutt Junior High School           | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 12/8/2017  | Orcutt Academy High School          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Orcutt          | 12/7/2017  | Pine Grove Elementary School        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |

Golden State Water Company  
School Lead Testing Results 3/2017 to 9/2019

|             |            |  |              |          |      |   |
|-------------|------------|--|--------------|----------|------|---|
| Orcutt      | 10/11/2018 | Righetti High School                                   | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Orcutt      | 10/11/2018 | Delta High School                                      | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/14/2018  | El Dorado High School                                  | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/14/2018  | Brookhaven Elementary School                           | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/15/2018  | Kraemer Middle School                                  | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/15/2018  | Valencia High School                                   | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/16/2018  | George Key School                                      | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/15/2018  | Golden Elementary School                               | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/22/2018  | Col. J.K. Tuffree Middle School & Parkview Home School | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/23/2018  | Morse Avenue Elementary School                         | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/23/2018  | Sierra Vista Elementary School                         | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/28/2018  | John O. Tynes Elementary School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 2/28/2018  | Ruby Drive Elementary School                           | Lead (total) | <5 - 5.7 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Placentia   | 3/1/2018   | El Camino Real Continuation High School                | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 3/2/2018   | Melrose Elementary School                              | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Placentia   | 3/2/2018   | Valadez Middle School Academy                          | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/26/2017  | Allen Avenue Elementary School                         | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/24/2017  | Arma J. Shull Elementary School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/26/2017  | Chaparral High School                                  | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/24/2017  | Fred Ekstrand Elementary School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/23/2017  | Gladstone Elementary School                            | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/31/2017  | Lone Hill Middle School                                | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/31/2017  | San Dimas High School                                  | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/15/2018  | Charter Oak High School                                | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/16/2018  | Badillo Elementary School                              | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/17/2018  | Cedargrove Elementary School                           | Lead (total) | <5 - 5.2 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| San Dimas   | 5/17/2018  | Glen Oak Elementary School                             | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 9/13/2017  | Arrow Montessori School                                | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| San Dimas   | 5/3/2018   | Montessori of San Dimas                                | Lead (total) | <5 - 9.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| San Dimas   | 8/22/2018  | Holy Name of Mary School                               | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Simi Valley | 4/5/2017   | Apollo High School                                     | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Simi Valley | 4/7/2017   | Atherwood Elementary School                            | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Simi Valley | 4/5/2017   | Berylwood Elementary School                            | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Simi Valley | 4/6/2017   | Garden Grove Elementary School                         | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Simi Valley | 4/7/2017   | Justin Early Learners                                  | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Simi Valley | 4/6/2017   | Knolls Elementary School                               | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Simi Valley | 4/5/2017   | Mountain View Elementary School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Simi Valley | 4/6/2017   | Santa Susana High School                               | Lead (total) | <5       | ug/L | All samples non-detect for lead   |

Golden State Water Company  
School Lead Testing Results 3/2017 to 9/2019

|               |            |                                       |              |          |      |  |
|---------------|------------|---------------------------------------|--------------|----------|------|--|
| Simi Valley   | 4/5/2017   | Simi Valley High School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Simi Valley   | 4/7/2017   | Sycamore Elementary School            | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Simi Valley   | 4/7/2017   | Vista Elementary School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Simi Valley   | 4/5/2017   | Simi Institute of Careers & Education | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Simi Valley   | 4/5/2017   | Simi Valley USD Transportation        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Sisquoc       | 3/28/2018  | Benjamin Foxen Elementary School      | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| South Arcadia | 3/21/2018  | Pearl Preparatory School              | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| South Arcadia | 4/26/2018  | Dr. Doug Sears Learning Center        | Lead (total) | <5 - 5.8 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| South Arcadia | 4/26/2018  | La Rosa Elementary School             | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| South Arcadia | 6/13/2019  | Plymouth Elementary School            | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 4/13/2017  | Leuzinger High School                 | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 4/13/2017  | Hawthorne High School                 | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 4/27/2017  | R. K. Lloyd High School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 4/27/2017  | Lawndale High School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 3/22/2017  | Junipero Serra High School            | Lead (total) | <5 - 5.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| Southwest     | 4/26/2017  | Carson Christian School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 8/30/2017  | Saint Anthony of Padua                | Lead (total) | <5 - 6   | ug/L | Two samples tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Southwest     | 4/10/2018  | Vanguard Learning Center              | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 4/10/2018  | Bunche Elementary School              | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 4/10/2018  | Enterprise Middle School              | Lead (total) | <5 - 9.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| Southwest     | 4/10/2018  | McKinley Elementary School            | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 5/1/2018   | Juan De Anza Elementary School        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 5/1/2018   | Peter Burnett Elementary School       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 5/1/2018   | Dana Middle School                    | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/15/2018  | FDR Elementary School                 | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/15/2018  | Carson School                         | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/12/2018  | Twain Elementary School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/12/2018  | Anderson Elementary School            | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/12/2018  | Rogers Middle School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/15/2018  | Green Elementary School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/5/2018   | Addams Middle School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/6/2018   | Smith Elementary School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 6/6/2018   | Mitchell Elementary School            | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 11/14/2018 | Bud Carson Elementary School          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 11/14/2018 | Zela Davis School E&W                 | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 11/14/2018 | Kornblum School                       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest     | 11/15/2018 | Worthington Elementary School         | Lead (total) | <5       | ug/L | All samples non-detect for lead  |

Golden State Water Company  
School Lead Testing Results 3/2017 to 9/2019

|             |                                   |   |              |          |      |  |
|-------------|-----------------------------------|---|--------------|----------|------|--|
| Southwest   | 1/29/2019                         | Environmental Charter Middle School - Inglewood | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 1/29/2019                         | Environmental Charter High School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 2/26/2019                         | Animo Watts College Preparatory School          | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 2/26/2019                         | Animo Mae Jemison Charter School                | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 3/26/2019                         | Children of Promise School                      | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 4/11/2019                         | New Designs Charter - Watts                     | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 4/23/2019                         | TEACH Tech Charter High School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 5/8/2019                          | Dolores Huerta Elementary School                | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 5/9/2019                          | Felton Elementary School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 5/14/2019                         | Jefferson Elementary School                     | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 5/16/2019                         | Moffett Elementary School                       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 5/16/2019                         | Lennox Middle Elementary School                 | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 5/21/2019                         | Buford Elementary School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Southwest   | 6/11/2019                         | Today's Fresh Start Charter - Inglewood         | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| Tanglewood  | 10/18/2017                        | Arellanas Elementary & Junior High School       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/4/2017                          | Los Alamitos Elementary School                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/6/2017                          | Lee Elementary School                           | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/6/2017                          | Weaver Elementary School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/6/2017                          | Hopkinson Elementary School                     | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/6/2017                          | Rossmoor Elementary School                      | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/4/2017                          | Los Alamitos High School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/4/2017                          | Oak Middle School                               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/4/2017                          | McAuliffe Middle School                         | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 4/11/2018                         | Cypress High School                             | Lead (total) | <5 - 6.0 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| West Orange | 5/24/2017                         | Robert M. Pyles Elementary School               | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 5/23/2017                         | Walter Elementary School                        | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 2/16/2018                         | Cypress Community College                       | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 6/21/2018                         | Margaret Landell Elementary School              | Lead (total) | <5 - 6.6 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| West Orange | 8/15/2018, 9/5/2018 and 9/18/2018 | A.E. Arnold Elementary School                   | Lead (total) | <5 - 120 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. The sample location was resampled but still had lead above the reporting limit. The school was advised to flush the sample location. All other school samples were non-detect for lead. |
| West Orange | 8/15/2018                         | Juliet Morris Elementary School                 | Lead (total) | <5 - 5.8 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| West Orange | 8/14/2018                         | Clara J. King Elementary School                 | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 8/14/2018                         | Frank Vessels Elementary School                 | Lead (total) | <5 - 9.9 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.  |
| West Orange | 8/28/2018                         | Del Sol School                                  | Lead (total) | <5       | ug/L | All samples non-detect for lead  |
| West Orange | 9/11/2018                         | Wisdom Mission School                           | Lead (total) | <5 - 11  | ug/L | Three samples tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead.   |

Golden State Water Company  
School Lead Testing Results 3/2017 to 9/2019

|             |           |                                  |              |          |      |   |
|-------------|-----------|----------------------------------|--------------|----------|------|---|
| West Orange | 9/11/2018 | Grace Christian School           | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Willowbrook | 4/3/2018  | Willowbrook Middle School        | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Willowbrook | 4/10/2018 | Chavez-Tubman Alternative School | Lead (total) | <5 - 5.2 | ug/L | One sample tested had lead above the reporting limit of 5 ppb. All other school samples were non-detect for lead. |
| Willowbrook | 4/10/2018 | Anderson Elementary School       | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Willowbrook | 4/10/2018 | MLK Jr Elementary School         | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Wrightwood  | 4/25/2018 | Wrightwood Elementary School     | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Yorba Linda | 2/20/2018 | Bernardo Yorba Middle School     | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Yorba Linda | 2/21/2018 | Fairmont Elementary School       | Lead (total) | <5       | ug/L | All samples non-detect for lead   |
| Yorba Linda | 3/1/2018  | Glenknoll Elementary School      | Lead (total) | <5       | ug/L | All samples non-detect for lead   |

***Please note: All samples were collected in the morning, before fixtures were used or flushed. Water that sits for extended periods of time in contact with lead-containing materials has a higher likelihood of containing lead than water from a tap or drinking fountain that is used often.***

***The drinking water action level for lead is 15 parts per billion (ppb). If a trace amount of lead is detected that is lower than the action level, schools will be advised to flush those faucets or fountains after extended periods of non-use. If samples exceed the action level, Golden State Water will work with those schools to develop a corrective action plan that may include extended flushing, faucet or fountain replacement, or discontinued use of the faucet or fountain.***